

Reduced Power Notification
Sinclair Telecable, Inc.
Station WTAR(AM), Norfolk, Virginia

WTAR(AM) Reduced Power Notification

Sinclair Telecable Inc. ("Sinclair") respectfully notifies the FCC that Station WTAR(AM), Norfolk, Virginia, is operating with 5 kW power during the day and night pursuant to Section 73.1560(d) of the Commission's Rules, due to partial failure of the transmitter's building air conditioning system. Reduced power is necessary in order to prevent overheating of the transmitter building and equipment inside pending repairs to the air conditioning. Sinclair is hopeful the repairs will be completed before the 30-day period has elapsed. If not, Sinclair will request Special Temporary Authority.