

Exhibit E-1
FCC 301
Section III B
Paragraph 17

RFR STATEMENT

Paragraph 17 of FCC form 301 section I. I. I. B. requires an assurance that the proposed facility will meet all radio frequency electromagnetic exposure limits for controlled and uncontrolled environments.

The proposed facilities of KGFX-FM will operate with a six bay circularly polarized antenna. The proposed facilities will operate with an ERP of 50 KW CP (100KW total) and a center radiation of 111.0 m AGL.

The proposed power density at two meters above the ground at the tower base will be .125mW/cm . This is 12.5% of the MPE for occupational/controlled areas. It is 62.5% of the MPE for general population/uncontrolled exposure.

Therefore the proposed facility meets all of the guidelines recommended by the FCC in bulletin OET 65.

The facility will be fenced with an eight-foot chain-link fence and three strands of Barb wire. The facility will also be marked with signs warning of RF radiation.

KGFX-FM will cooperate by reducing power or ceasing operation as is appropriate when necessary maintenance is to be done.